

Battery Test Report

Model	BLD-75EXDT	Date	October 1, 2019
		T_{amb}	24° Celsius

Time	I (Ampere)	V (Volt)	P (Watt)
14:00	1.79	16.76	30.0
14:15	1.92	15.61	30.0
14:30	1.94	15.48	30.0
15:00	2.01	14.86	29.9
15:30	2.10	14.27	30.0
16:00	2.18	13.71	29.9
16:30	2.28	13.12	29.9
16:50	2.47	12.22	30.2
16:55	2.90	10.50	30.5

Total duration (h)	2:55	2.92
Nominal energy	75.0 Wh	
Measured energy	87.5 Wh	16% over

Meter/Tester	DC Electronic Load	TekPower	Mod 3711A
	Metter Settings		
	Constant Power	30W	
	Max Current	3A	
	Min Voltage	10V	

Ricardo F. Kauffmann - BScEE, IES

CREA 33242-D

www.energia.tv